

ORDINANCE NO. 2627

AN ORDINANCE AMENDING CHAPTER 16.36 OF THE MOSES LAKE MUNICIPAL CODE ENTITLED "FIRE CODE"


THE CITY COUNCIL OF THE CITY OF MOSES LAKE, WASHINGTON ORDAINS AS FOLLOWS:

Section 1. Chapter 16.36 of the Moses Lake Municipal Code entitled "Fire Code" is amended as follows:

16.36.050 Fire Department Connection Requirements: The top of the Fire Department connection shall not be more than forty-four inches(44") nor less than thirty-six inches (36") above grade. All Fire Department connection riser piping shall be painted red from grade to just below the threaded connection for the hose cap.

Section 2. This ordinance shall take effect and be in force five (5) days after its passage and publication of its summary as provided by law.

Adopted by the City Council and signed by its Mayor on September 13, 2011.

  
\_\_\_\_\_  
Jon Lane, Mayor

ATTEST:

  
\_\_\_\_\_  
Ronald R. Cone, Finance Director

APPROVED AS TO FORM:

  
\_\_\_\_\_  
Katherine L. Kenison, City Attorney