

ORDINANCE NO. 2659

AN ORDINANCE AMENDING CHAPTER 13.12 OF THE MOSES LAKE MUNICIPAL CODE ENTITLED "WATER, SEWER, AND STORMWATER RATES"

THE CITY COUNCIL OF THE CITY OF MOSES LAKE, WASHINGTON ORDAINS AS FOLLOWS:


Section 1. Chapter 13.12 of the Moses Lake Municipal Code entitled "Water, Sewer, and Stormwater Rates" is amended as follows:

13.12.100 Fire Protection Charges:

- A. Metering shall not be required for fire protection lines running directly to buildings when used solely for furnishing water to sprinkler, or other fire protection systems. Water flow alarms shall be provided in all fire protection sprinkler installations. Such alarms shall be either water motor or electric gongs, except where alternate devices are specifically approved by the city.
  
- B. Water supplied to above ground or underground tanks for deluge systems from which water is pumped for fire protection service shall be metered and payment shall be made for water actually consumed at the established rate on commercial accounts. There shall be no minimum monthly amount charged.

Section 2. This ordinance shall take effect and be in force five (5) days after its passage and publication of its summary as provided by law.


Adopted by the City Council and signed by its Mayor on October 9, 2012.



---

Bill J. Ecret, Mayor

ATTEST:



---

W. Robert Taylor, Finance Director

APPROVED AS TO FORM:



---

Katherine L. Kenison, City Attorney