



September 2, 2021

TO: All Planholders – Municipal Airport Fuel Storage Project

SUBJECT: Addendum #2

Enclosed please find Addendum #2, consisting of 1 page, to the above-named project specifications. Please carefully note the changes, sign, and return this page at the time of bidding. Your signature on this page indicates you have received the entire addendum.

Sincerely,

Mark Beaulieu, P.E.
Design Engineer
Municipal Services Department

MB:ll
Enclosure

cc Municipal Services Director
City Engineer – Richard A. Law, P.E.
Mike Moro, P.E. – Public Works Division Director

Name of Firm _____

By _____ Title _____

**CONTRACT NO. GC2021-042
MUNICIPAL AIRPORT FUEL PROJECT
ADDENDUM NO. 2**

The following changes have been made to the plans and specifications for the above-named project. Please incorporate the following information into your bid.

The cover sheet of this addendum **must** be signed and returned with your proposal at the time set for the bid opening.

NOTICE TO CONTRACTORS

None.

PROPOSAL

None.

SPECIAL PROVISIONS

The following strike-through text is deleted from Section 8-26.2:

~~D1655 Specification for Aviation Turbine Fuels~~

~~Military Specification Mil C 4556 Coating Kit, Epoxy, for interior of steel fuel tanks~~

The following strike-through text is deleted from Section 8-26.11.1:

~~Exterior coatings shall be two coat systems of epoxy paint qualified to meet specification MIL-C4556-D and shall be applied in accordance with the manufacturer's instructions. All procedures shall be approved by the coating manufacturer's representatives. The total dry film thickness of the coating shall at least 5-7 mils.~~

PLANS

None.

END OF ADDENDUM