



September 17, 2021

TO: All Planholders – Municipal Airport Fuel Storage Project

SUBJECT: Addendum #3

Enclosed please find Addendum #3, consisting of 1 page, to the above-named project specifications. Please carefully note the changes, sign, and return this page at the time of bidding. Your signature on this page indicates you have received the entire addendum.

Sincerely,

Mark Beaulieu, P.E.
Design Engineer
Municipal Services Department

MB:ll
Enclosure

cc Municipal Services Director
City Engineer – Richard A. Law, P.E.
Mike Moro, P.E. – Public Works Division Director

Name of Firm _____

By _____ Title _____

**CONTRACT NO. GC2021-042
MUNICIPAL AIRPORT FUEL PROJECT
ADDENDUM NO. 3**

The following changes have been made to the plans and specifications for the above-named project. Please incorporate the following information into your bid.

The cover sheet of this addendum **must** be signed and returned with your proposal at the time set for the bid opening.

NOTICE TO CONTRACTORS

None.

PROPOSAL

None.

SPECIAL PROVISIONS

The following text is added to Section 8-26.1.

The piping and valves for the self-service fuel tank and dispensing unit shall be welded stainless steel 304, schedule 10. Fittings shall be butt welded. All flanges used shall be Class 150 raised face slip on stainless steel 304 and shall be welded internally and externally. All valves shall be firesafe stainless steel 304 with Class 150 slip on flanges and with seats and seals approved for use with Avgas 100LL.

PLANS

None.

END OF ADDENDUM